

Slate**Spacer**[™] specification, US

1 December, 2008

PART I - GENERAL

I.1 SUMMARY

A. WORK INCLUDES

1. Slate**Spacer**[™]
2. Provide appropriate Slate**Spacer**[™]s for the roof system.

B. RELATED SECTIONS

1. Division 7: Thermal and Moisture Protection.
2. Section 07310: Natural Slate Shingles.
3. Section 07600: Flashing and Sheet Metal.

I.2 SYSTEM DESCRIPTION

A. COMPONENTS:

1. Standard Slate**Spacer**[™]
2. Edge Slate**Spacer**[™]

B. DESIGN REQUIREMENTS:

1. Joint space: horizontally adjacent slates should be a minimum of 5/32" (3 mm) apart

I.3 SUBMITTAL - Submit manufacturer's Installation Guide.

I.4 QUALITY ASSURANCE – Installer to be experienced in the installation of roofing slate, having applied at least four complete slate roofs for not less than 4 years in the area of the project.

I.5 DELIVERY / STORAGE / HANDLING - Inspect material upon delivery and order replacements for any missing or defective items.

PART 2 – PRODUCTS

2.1 MANUFACTURER

- A. Ardelis LLC, 1220 N. Market St., Suite 806, Wilmington, Delaware, 19801, USA;
www.slatespacer.com; email: slate@slatespacer.com;
telephone +1 302 652 0834, fax +1 302 652 6656

2.2 MATERIALS

- A. Standard and Edge Slate**Spacer**[™]
- B. Stainless steel, 302 or 304 (unless otherwise specified)

2.3 FINISH - All spacers provided mill finish.

PART 3 - EXECUTION

3.1 SLATE INSTALLATION

- A. Joint space: Leave a minimum of 5/32" (3 mm) between horizontally adjacent slates.

3.2 SLATE**SPACER**[™] INSTALLATION

- A. Comply with manufacturer's Installation Guidelines.